

## KTS-MW3-UV-KO-K1

### LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR

#### DESCRIPTION

LED Microwave Occupancy/Daylight Sensor |  
 Performance Parameters Set by Remote Control  
 (sold separately)

**INPUT VOLTAGE:** 12Vdc  $\pm$  2Vdc

**MICROWAVE FREQUENCY:** 5.8 GHz  $\pm$  75MHz

**OUTPUT VOLTAGE:** 0–10Vdc

**TRANSMIT POWER:** <0.5mW



RoHS  
Compliant



**5 YEAR**  
WARRANTY

#### PRODUCT FEATURES

- Partial discharge (PD) dual-technology differentiates artificial light brightness from natural light and automatically turns off light when ambient brightness exceeds preset lux level\*
- Microwave sensing technology detects motion in the coverage area and automatically turns off light when motion is no longer detected\*
- Adjustable angle sensor head and bronze housing color; Ideal for outdoor wallpack fixtures
- Installs through standard ½" knock-out (KO) on fixtures
- Powered by dedicated 12Vdc power source, included with sensor kit, OR 12V AUX tap directly from LED driver (if applicable)
- Adjustable performance parameters set by Keystone remote control (sold separately)
- Ambient operating temperature: –30°C/–22°F to 60°C/140°F
- IP Rating: IP65

\*Fixture only turns off if using a dim-to-off driver. Without dim-to-off driver, the fixture will dim down to its lowest allowable light level.

#### PERFORMANCE SPECIFICATIONS

Microwave Frequency	Input Voltage	Input Current	Output Voltage	Transmit Power	Stand-By Power	Max Mounting Height	Detection Angle	Detection Range
5.8GHz	12Vdc	30mA	0–10V	<0.5mW	<0.5W	49' (ceiling mount)	30°–150°	Ceiling mount: Ø 49' max Wall mount: 66' max

#### ADJUSTABLE SETTINGS

Brightness	Sensitivity	Hold Time	Daylight Threshold	Stand-By Time	Stand-By Dimming Level
70%	20%	10 sec	10 Lux	1 min	10%
80%	50%	1 min	30 Lux	30 min	20%
90%	75%	10 min	50 Lux	60 min	30%
100%	100%	30 min	100 Lux	∞	50%
			Disable		

#### FACTORY PRESETS

Hold Time	Daylight Threshold	Stand-By Time	Stand-By Dim Level
10 min	Disabled	∞	50%

#### STARTUP BEHAVIOR


When fixture power is applied, the below startup sequence occurs

1. Light output 100%, red indicator on
2. After 10s, light output 50%, red indicator off
3. Sensor is now ready for normal operation




# KTS-MW3-UV-KO-K1

## LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR

**PHYSICAL SPECIFICATIONS**



**WIRING DIAGRAMS**






# KTS-MW3-UV-KO-K1


## LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR

### DETECTION COVERAGE

CEILING MOUNT (Top View)



WALL MOUNT (Top View)



Well-covered Covered

# KTS-MW3-UV-KO-K1

## LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR


### LUX ON/OFF SETTING

#### FUNCTION


Partial discharge (PD) dual-technology differentiates artificial light brightness from natural light and automatically turns off light when ambient brightness exceeds preset lux level.

Lux-Off function preconditions:

- Stand-by period setting: ∞
- Stand-by dimming level setting: 10%, 20%, 30%, or 50%
- Daylight threshold setting: 10 Lux, 30 Lux, 50 Lux, or 100 Lux



#### APPLICATION




When ambient light is lower than preset lux level, lighting will turn on and remain at preset stand-by dimming level.



With insufficient ambient light, when motion is detected, lighting will turn on and remain at preset brightness level until motion is no longer detected for duration of preset hold time.



If no further motion is detected after duration of hold time, lighting will dim and remain at preset brightness level for duration of standby time or until ambient light level exceeds preset lux level.




When ambient light reaches preset lux level, lighting will turn off and remain off until ambient light level falls below preset lux level.

**KTS-MW3-UV-KO-K1**  
LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR

**INSTALLATION**

1. Ensure power is off to the fixture.
2. Remove 1/2" knock-out (KO) plug from applicable fixture.
3. Twist sensor into the KO plug hole.
4. Lock sensor in place with nut.
5. Wire sensor to fixture.
6. Re-connect power when ready.
7. Adjust sensor angle to desired position.
8. Program desired settings as needed with Keystone Remote Control.



**ACCESSORY (SOLD SEPARATELY)**

**REMOTE CONTROL**

Catalog Number	Description	UPC	Easy Code
KTS-MW3-REMOTECONTROL	Remote Control for KTS-MW3-12V-XX Sensors, Sets/adjusts all sensor performance parameters	843654132020	XSR-61





# KTS-MW3-UV-KO-K1

## LED MICROWAVE OCCUPANCY/DAYLIGHT SENSOR

### ORDERING INFORMATION

ORDER CODE	PACK QTY.	UPC	Easy Code
KTS-MW3-UV-KO-K1	1	843654134147	BKG-51

### CATALOG NUMBER BREAKDOWN

# KTS-MW3-UV-KO-K1

1

2

3

4

5

- 1 Keystone Technologies Sensor
- 2 Microwave Sensor Form Factor
- 3 0–10V
- 4 Knock Out
- 5 Kit 1